

**Labor für Umwelterprobung
und Werkstoffprüfung**

Telefon +49 (0) 3 41 / 4 84 32 - 25
Telefax +49 (0) 3 41 / 4 84 32 - 14
E-Mail umwelterprobung@tzoleipzig.de

**Technologie-Zentrum für Oberflächentechnik
und Umweltschutz Leipzig GmbH**

Hornstraße 5 • D-04249 Leipzig
Telefon +49 (0) 3 41 / 4 84 32 - 0 • Fax +49 (0) 3 41 / 4 84 32 - 14
E-Mail info@tzoleipzig.de

TEST CERTIFICATE

Client ROLEC Gehäuse-Systeme GmbH
Kreuzbreite 2
D – 31737 Rinteln

Date of order 2015-01-09

TEST OBJECT

Enclosure of series technoPlus TP090
technoPlus TP092
technoPlus TP110
technoPlus TP132
technoPlus TP172

**The certificate is valid in connection with the test report
No. 008b/15**

The specimens were tested in accordance with ISO 20653 : 2013–02 to determine the degree of protection IP Code X9K.

Criterion for passing the tests

- IP X9K No water shall enter into the enclosure.

TEST DECISION

The specimens have passed the above mentioned test.

Leipzig, 2015-01-13

**Laboratory for Environmental
Testing and Material Testing**

Dr.-Ing. Frank Erlen
Laboratory Manager